

Ensure all coils are fitted in the same orientation with the arrow pointed towards the load

Rogowski Coil and Rogowski Integrator Accessory No. RC0005

**Meter**  
Item code: M0015


MeanWell PSU Accessory No. A6001

Negative supply terminal MUST be connected to earth

230V Grid Auxiliary Supply - Fused

AUX Must be connected to power meter

**Must be installed by authorised person**

 GOODMEASURE™	© 2016 EMBRIUM HOLDINGS LIMITED - ALL RIGHTS RESERVED
Title: SDM630mv-CT meter with Rogowski Coils	
Date: 30.11.17	Client:
Reviewed by: <i>MW</i>	Project:
File: M0015 SDM630MV-CT with Rogowski Coils.pdf	

1

2

3

4

5

6

7

E