



Integrator and Couplers connected to EDM I meters



- Notes:
- Integrator/Connector must pass through unsolicited EDM I commandline traffic
 - The Integrator/Connector should back off for period if unsolicited traffic detected
 - The Integrator/Connector may query any of the meters using the commandline protocol

 © 2019 FINANCIAL CORPORATION LIMITED - ALL RIGHTS RESERVED	
Title: Integrator and Coupler Meter Connection	
Date: 31.03.2017	Client:
Reviewed by: Mark	Project:
File: Integrator and Coupler Meter Connection	